



Ref. Certif. No.

HU-002755

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breaker for overcurrent protection

Name and address of the applicant

Zhejiang ETEK Electrical Technology Co., Ltd.
NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province, P.R. China

Name and address of the manufacturer

Zhejiang ETEK Electrical Technology Co., Ltd.
NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province, P.R. China

Name and address of the factory

Zhejiang ETEK Electrical Technology Co., Ltd.
NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue = 230V/400~ (1P), 400V~ (2P/3P/4P); Uimp=6 kV
In=1A, 2A, 4A, 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
(B/C- type);
In=6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A (D- type)
for EKM1-63
Icn=10kA; Ics=7,5kA for EKM1-63H; Icn= Ics=6,0kA
for EKM1-63; Class 3
(see Test Report for further ratings)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EKM1-63, EKM1-63H

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015
EU Group Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

1W190442

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.com

Date: 2019-10-22

Signature:



Tünde Potencsik