



Ref. Certif. No.

FR_712917

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker

Miniature Circuit Breaker

Name and address of the applicant

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province - China

Name and address of the manufacturer

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province - China

Name and address of the factory

ZHEJIANG ETEK Electrical technology CO.,LTD

NO.288 Wei17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province - China

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

ET3K

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

EKM3-63
See Annex

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 +A1:2010 +A2:2014
IEC 60947-2:2016 +A1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

B210095

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 20/12/2021

Signature: **Julien Gauthier**

Certification Officer



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES

ANNEX

References, ratings and main characteristics:

	1P	2P	3P	4P
1A	011	012	013	014
2A	021	022	023	024
3A	031	032	033	034
4A	041	042	043	044
5A	051	052	053	054
6A	061	062	063	064
8A	081	082	082	084
10A	101	102	102	104
13A	131	132	132	134
16A	161	162	162	164
20A	201	202	202	204
25A	251	252	252	254
32A	321	322	322	324
40A	401	402	402	404
50A	501	502	502	504
63A	631	632	632	634



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 20/12/2021

Signature:  **Julien Gauthier**
Certification Officer




LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES

Utilization category	A
Interruption medium	Air
Design	Moulded case
Method of controlling the operating mechanism	Dependent manual
Suitability for isolation	Suitable
Provision for maintenance	Non-maintainable
Method of installation	Fixed
Protection degree :	IP20 for front cover
Rated operational voltage U_e : (V)	230V~ or 240V~(1P);400V or 415V~(2P/3P/4P)
Rated insulation voltage U_i : (V)	500V
Rated impulse withstand voltage U_{imp} : (V)	6kV
Rated current I_e : (A)	1A;2A;3A;4A;5A;6A;8A;10A;13A;16A;20A;25A;32A;40A;50A;63A
Conventional free air thermal current I_{th} : (A)	63A
Conventional enclosed thermal current I_{the} : (A)	N/A
Rated current for four pole circuit-breakers : (A)	63A
Rated frequency : (Hz)	50/60Hz
Nature of supply :	~
Total number of poles :	1P;2P;3P;4P
Number of protected poles :	1P;2P;3P;4P
Rated duty	Uninterrupted duty
Rated short-time making capacity I_{cm} : (A)	10,2kA
Rated ultimate short-circuit breaking capacity I_{cu} : (A)	6kA
Rated service short-circuit breaking capacity I_{cs} : (A)	6kA
Rated short-time withstand current I_{cw} : (A)	N/A
Electromagnetic compatibility	Thermo-magnetic
Instantaneous tripping current :	10In
Reference ambient calibration air temperature : ($^{\circ}$ C)	30 $^{\circ}$ C
Pollution degree	2
Material group :	IIIa
safety distance (short-circuit tests) :	Back:0mm Front:0mm Up:50mm Down:50mm Left:0mm Right:0mm



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 20/12/2021

Signature:  Julien Gauthier
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES